

# Certificate of Compliance

## Certificate

252655-410

## Issue Date

25 Oct 2021

## Expiry Date

25 Oct 2026



Rane Valles  
Director and General Manager

UL Verification Services Inc.  
2211 Newmarket Parkway, ste 106  
Marietta, GA 30067 USA

UL Verification Services does hereby certify that an independent assessment has been conducted on behalf of:

## Dunlop Adhesives (Thailand) Limited

for the following product:

## DAT SP Low Smell Adhesive

The product has been evaluated and meets the requirements for:

## GREENGUARD™

UL 2818 - 2022 Standard for Chemical Emissions for Building Materials, Finishes and Furnishings

*Commercial furniture and furnishings are tested in accordance with ANSI/BIFMA M7.1-2011(R2016) and determined to comply with ANSI/BIFMA X7.1-2011(R2016) and ANSI/BIFMA e3-2019 Credit 7.6.1 in a Private Office environment.*

# Certificate of Compliance

## GREENGUARD Certification Criteria for Building Products and Interior Finishes

| Criteria                                       | CAS Number | Maximum Allowable Predicted Concentration | Units             |
|--|------------|---|-------------------|
| TVOC <sup>(A)</sup>                            | -          | 0.50                                      | mg/m <sup>3</sup> |
| Formaldehyde                                   | 50-00-0    | 61.3 (50 ppb)                             | µg/m <sup>3</sup> |
| Total Aldehydes <sup>(B)</sup>                 | -          | 0.10                                      | ppm               |
| Particle Matter less than 10 µm <sup>(C)</sup> | -          | 50  | µg/m <sup>3</sup> |
| 4-Phenylcyclohexene                            | 4994-16-5  | 6.5                                       | µg/m <sup>3</sup> |
| Individual VOCs <sup>(D)</sup>                 | -          | 1/10th TLV                                | -                 |

- (A) Defined to be the total response of measured VOCs falling within the C<sub>6</sub> – C<sub>16</sub> range, with responses calibrated to a toluene surrogate. Maximum allowable predicted TVOC concentrations for GREENGUARD (0.50 mg/m<sup>3</sup>) fall in the range of 0.5 mg/m<sup>3</sup> or less, as specified in CDPH Standard Method v1.2.
- (B) The sum of all measured normal aldehydes from formaldehyde through nonanal, plus benzaldehyde, individually calibrated to a compound specific standard. Heptanal through nonanal are measured via TD/GC/MS analysis and the remaining aldehydes are measured using HPLC/UV analysis.
- (C) Particle emission requirement only applicable to HVAC Duct Products with exposed surface area in air streams (a forced air test with specific test method) and for wood finishing (sanding) systems.
- (D) Allowable levels for chemicals not listed are derived from 1/10th of the Threshold Limit Value (TLV) industrial work place standard (Reference: American Conference of Government Industrial Hygienists, 6500 Glenway, Building D-7, and Cincinnati, OH 45211-4438).